

## ASI No. 22

<i>to</i>	<b>DELTERA</b> 4800 Dufferin Street Toronto Ontario M3H 5S9	<i>project:</i>	<b>SQ ALEXANDRA PARK BLOCK 11 CONDOMINIUM</b>
<i>attention</i>	<b>FRED FOO</b> ffoo@deltera.com	<i>project no.:</i>	<b>12-115</b>
		<i>date:</i>	<b>January 6, 2016</b>

Site Instructions are issued for the purposes of recording any clarification or interpretation of the contract documents or giving direction on problems resulting from field conditions. These instructions are subject to the provisions of the contract documents and unless stated herein and specifically authorized by the Client, will not affect the contract. Should the Contractor require a change in the contract price or project schedule, he shall submit to the Architect an itemized proposal. If the Client accepts the proposal, a Change Order will supersede this Site Instruction. When used as a Field Order, the Instruction should clearly state the accounting basis on which the work is to proceed and whether there is a change to the proposed schedule.

**1. TITLE**

(1 page)

Gypsum Board Bulkhead Revisions

**2. REFERENCES**

A221 Level 10 Plan (enclosed)  
A222 Level 11 Plan (enclosed)  
A261 RCP Ground (enclosed)  
A702 Stair Plans and Sections (enclosed)  
A802 Interior Details (enclosed)

**3. DESCRIPTION OF WORK**A 221

- .1 Partition dimensions and bulkheads revised as noted at suite 1014 in compliance with OBC guidelines for combination rooms.

A 222

- .1 Partition dimensions and bulkheads revised as noted at suite 1114 in compliance with OBC guidelines for combination rooms.

A 261, A702, A802

- .1 2-hour FRR bulkhead noted at end of Corridor A and Corridor B.

**4. REASONS**

Design coordination

**END OF SITE INSTRUCTION ASI No. 22**

Tanya Cazzin OAA

