


6TH FLOOR FRAMING PLAN

SCALE 1:100

1. TOP OF SLAB IS AT ELEVATION AS SHOWN ON ARCH. DRAWINGS EXCEPT AS CROSSED AND NOTED ON PLAN.
2. CONCRETE STRENGTH AT 28 DAYS SHALL BE:
FOR WALLS AND COLUMNS SEE SCHEDULE FOR EXT. SLABS 35 MPa
FOR INTERIOR SLABS 35 MPa
FOR BEAMS 35 MPa
CONCRETE EXPOSED TO ELEMENTS SHALL BE 35 MPa WITH 6% TO BE ENRICHED AIR.
3. FLOOR SLABS ARE DESIGNED FOR FOLLOWING LOADING CONDITIONS:

	S.L.D.	L.L.
STAIRS & BALCONIES	0.50 kPa	4.80 kPa
LOBBIES & STORAGE	1.50 kPa	4.80 kPa
RESIDENTIAL	1.50 kPa	1.9 kPa
TOILETS	1.50 kPa	2.40 kPa
TERACES	5.0 kPa	4.80 kPa




DIRECTION OF REINFORCING OF THE SLAB	TYPE
TL & BT	TL & BT
TL & BT	TL & BT

4. MINIMUM YIELD STRESS FOR REINFORCING STEEL SHALL BE 400 MPa.
5. TEMPERATURE REINFORCING FOR: 200 SLAB IS 100%
210 SLAB IS 100%
210 SLAB IS 100%
6. NO OPENINGS LARGER THAN 300mm x 300mm ARE ALLOWED IN SLAB STRIPS FROM FINISH SURFACE TO FINISH SURFACE.
7. SEE TYPICAL DETAILS ON DRAWINGS S-1001 TO S-1005.
8. SEE GENERAL NOTES ON DRAWING S-1001.
9. REFER TO ARCH. DRAWINGS FOR SLOPES OF SLAB.
10. FOR COLUMN & WALL SCHEDULE SEE DRAWINGS S-1001 TO S-1006.
11. COORDINATE BEAM DEPTH AT DOOR OPENINGS WITH ARCH. DRAWINGS.
12. EXTEND TOP REIN. TO END OF BALCONIES/OVERHANGS.
13. TOP BARS TERMINATING AT EDGE OF SLAB TO HAVE 180° HOOK.

FIRST FLOOR ELEV. 88.00m

NO.	REVISION/REMARK	DATE
1	ISSUED FOR PERMIT	08/08/2014
2	REVISION FOR COMMENTS	20/08/2014
3	REVISION FOR COMMENTS	20/08/2014
4	REVISION FOR COMMENTS	20/08/2014
5	REVISION FOR COMMENTS	20/08/2014
6	REVISION FOR COMMENTS	20/08/2014
7	REVISION FOR COMMENTS	20/08/2014
8	REVISION FOR COMMENTS	20/08/2014
9	REVISION FOR COMMENTS	20/08/2014
10	REVISION FOR COMMENTS	20/08/2014
11	REVISION FOR COMMENTS	20/08/2014
12	REVISION FOR COMMENTS	20/08/2014
13	REVISION FOR COMMENTS	20/08/2014
14	REVISION FOR COMMENTS	20/08/2014
15	REVISION FOR COMMENTS	20/08/2014
16	REVISION FOR COMMENTS	20/08/2014

Joblonsky, Asi and Partners ENGINEERS
 1100 SHEPPARD AVENUE EAST
 SUITE 1000
 SCARBOROUGH, ONTARIO M1B 2Y1
 TEL: 416-441-2700
 FAX: 416-441-2701
 E-MAIL: REVISION@JAP.COM



ALEXANDRA PARK - BLOCK 11
 TORONTO, ONTARIO

DATE: 11/08/14
 DRAWN BY: JAW
 CHECKED BY: JAW
 DATE: 11/08/14