


9TH FLOOR FRAMING PLAN
SCALE 1 : 100

- TOP OF SLAB IS AT ELEVATION AS SHOWN ON ARCH. DRAWINGS EXCEPT AS CROSSED AND NOTED ON PLAN.
- CONCRETE STRENGTH AT 28 DAYS SHALL BE:
FOR WALLS AND COLUMNS SEE SCHEDULE FOR EXIST. SLABS 35 MPa
FOR EXIST. SLABS 35 MPa
FOR BEAMS 35 MPa
CONCRETE EXPOSED TO ELEMENTS SHALL BE 35 MPa WITH 6% TO BE OBTAINED AS
- FLOOR SLABS ARE DESIGNED FOR FOLLOWING LOADING CONDITIONS :


	S.L.D.	L.L.
STAIRS & BALCONIES	0.50 KPa	4.80 KPa
LOOKERS & STORAGE *	1.50 KPa	4.80 KPa
RESIDENTIAL	1.50 KPa	1.9 KPa
TOILETS	1.50 KPa	2.40 KPa
TERMINALS	5.0 KPa	4.80 KPa



- MINIMUM YIELD STRESS FOR REINFORCING STEEL SHALL BE 400 MPa.
- TEMPERATURE REINFORCING FOR : 200 SLAB IS 1025X0.
- NO OPENINGS LARGER THAN 300mm x 300mm ARE ALLOWED IN SLAB OTHER THAN THOSE SHOWN ON DRAWINGS.
- SEE TYPICAL DETAILS ON DRAWINGS S-001 TO S-006.
- SEE GENERAL NOTES ON DRAWINGS S-001.
- REFER TO ARCH. DRAWINGS FOR SLOPES OF SLAB.
- FOR COLUMN & WALL SCHEDULE SEE DRAWINGS S-010 TO S-016.
- CORRODATE BEAM DEPTH AT DOOR OPENINGS WITH ARCH. DRAWINGS.
- EXTEND TOP REINFORCING TO END OF BALCONIES/OPENINGS.
- TOP BARS TERMINATING AT EDGE OF SLAB TO HAVE 180° HOOK.

PARTIAL PLAN OF THE HOT TUB SLAB
SCALE 1 : 100

NOTE: CONCRETE STRENGTH AT 28 DAYS SHALL BE 35 MPa. CONCRETE EXPOSED TO ELEMENTS SHALL BE REINFORCED FOR C-1 EXPOSURE CLASSIFICATION AND HAVE RATE OF 100 LITRES PER 1.0 CUBIC METRE OF CONCRETE.



Joblonsky, Asif
Civil & Structural
ENGINEERS
200 W. LESLIE ST. SUITE 205
TORONTO, ONT. M2H 2E5
Tel: 416-441-2777
E-mail: joblonsky@jce.ca

FIRST FLOOR ELEV. 80.00m

No.	Issued / Revisions	Date
1	Issued for Review	2016-01-18
2	Revised for Comments	2016-01-20
3	Revised for Comments	2016-01-20
4	Revised for Comments	2016-01-20
5	Revised for Comments	2016-01-20
6	Revised for Comments	2016-01-20
7	Revised for Comments	2016-01-20
8	Revised for Comments	2016-01-20
9	Revised for Comments	2016-01-20
10	Revised for Comments	2016-01-20
11	Revised for Comments	2016-01-20
12	Revised for Comments	2016-01-20
13	Revised for Comments	2016-01-20
14	Revised for Comments	2016-01-20
15	Revised for Comments	2016-01-20
16	Revised for Comments	2016-01-20

ALEXANDRA PARK - BLOCK 11
TORONTO, ONTARIO

DATE: 2016-01-18
DRAWN BY: JAS
CHECKED BY: JAS
DATE: 2016-01-18