


| GENERAL AREA CIRCUITING - TABLE *1 | |
|---|---|
| LIGHTING FIXTURE LOCATION | CCT.* |
| P2 TO P1 + EXIT SIGNS | E-1 |
| G/F TO MPH + EXIT SINGS | E-3 |
| MPH + EXIT SIGNS | ER-1 |
| STAIR "A" (P2 TO G/F) | E-5 |
| STAIR "B" (P2 TO G/F) | E-7 |
| STAIR "J" (G/F TO 4/F) | E-9 |
| STAIR "J" (5/F TO 9/F) | E-11 |
| STAIR "G" (G/F TO 14/F) | E-13 |
| STAIR "F" (G/F TO 14/F) | E-15 |
| STAIR "K" (14F TO MPH) & MPH | ER-3,ER-5,R-17,R-19 |
| (G/F) | E-2,E-4,E-6,E-16,E-8,E-18,E-10,E-12,E-14,E-16 |
| (G/F) | B1-2,B1-4,B1-6,B1-8,B1-10,B1-12,B1-14,B1-16, B1-18,B1-20,B1-22,B1-24,B1-26,B1-28,B1-30 |
| CORRIDOR (2/F & 3/F) | E-24 |
| CORRIDOR (4/F & 5/F) | E-26 |
| CORRIDOR (6/F & 7/F) | E-28 |
| CORRIDOR (8/F TO 11/F) | E-30 |
| CORRIDOR (12/F TO 14/F) | E-32 |
| CORRIDOR & LOCKER (2/F) | B-46 |
| CORRIDOR (3/F) | B-48 |
| CORRIDOR (4/F) | B-50 |
| CORRIDOR (5/F & 6/F) | B-52 |
| CORRIDOR (7/F & 8/F) | B-54 |
| CORRIDOR (9/F TO 11/F) | B-56 |
| CORRIDOR (12/F TO 14/F) | B-58 |
| ELEVATOR CAB | ER-6, ER-8,ER-10 |
| EXTERIOR SITE | E1-1,E1-3,E1-5,E1-2,E1-4,E1-6 |
| RECEPTACLE LOCATION | CCT.* |
| ELEC. 9, CLOSET (G/F TO 9/F) | B-2 |
| ELEC. N. CLOSET (2/F TO 9/F) | B-4 |
| ELEC. N. CLOSET (10/F TO 14/F) | B-6 |
| ELEC. N. CLOSET (22/F TO 32/F) | B-8 |
| ELEV. LOBBY (P2 TO 8/F) | B-10 |
| CORRIDOR (2/F TO 8/F) | B-12,B-14,B-16,B-18,B-20,B-22,B-24 |
| CORRIDOR (2/F TO 5/F) | B-26,B-28 |
| ELEV. LOBBY (9 TO 14/F) | B-30 |
| CORRIDOR (9/F TO 14/F) | B-32,B-34,B-36,B-38 |
| STAIR A (G/F) & 3/9/F6/F,3/F) | B-40 |
| STAIR F (14/F,1/F,B/F,5/F,2/F) | B-42 |
| STAIR H (14/F,1/F,B/F,5/F,2/F) | B-44 |
| STAIR "K" & MPH | R-2 |

## GENERAL NOTES - ROOF:

1. ELECTRICAL DRAWINGS SHALL BE READ IN CONJUNCTION WITH MECHANICAL, STRUCTURAL, ARCHITECTURAL AND LANDSCAPE DRAWINGS.
2. PROVIDE ALARM SPEAKER, SMOKE DETECTOR AND RECEPTACLE AT EVERY THIRD FLOOR STAIR WELL STARTING FROM TOP FLOOR, AS PER TO DWG. E-32 FOR FIRE ALARM RISER DIAGRAM. INSTALL SIDE-MOUNTED RECEPTACLE ON KITCHEN ISLAND CABINET.
3. CONTRACTOR SHALL RUN CABLES WITHIN CEILING SLAB OR ENCLOSURES TO RETAIN 2 HOUR FIRE PROTECTION RATING FOR ALL LOADS THAT CONNECT TO EMERGENCY POWER.
4. FIRE ALARM RISERS SHALL BE RUN IN 2 HOUR FIRE RATED ELECTRICAL CLOSET. REFER TO DWG. E-32 FOR RISER DIAGRAM AND DETAILS.
5. STAIRWAY WALL MOUNTED EMERGENCY LIGHT FIXTURES SHALL BE MOUNTED @ 7' A.F.F. MINIMUM.
6. FOR STORAGE ROOM VENTILATION SYSTEM, DIV. 16 TO PROVIDE CONDUIT, WIRING AND SWITCH (S) TO START/STOP FAN AND DAMPER. FAN AND 110V ACTUATOR TO BE SUPPLIED AND INSTALLED BY DIV. 15.
7. FOR UTILITY ROOM VENTILATION SYSTEM, DIV. 15 WILL PROVIDE LINE VOLTAGE THERMOSTAT (T) TO DIV. 16. DIV. 16 TO PROVIDE CONDUIT AND WIRING TO START/STOP FAN AND DAMPER VIA THERMOSTAT. FAN AND 110V ACTUATOR TO BE SUPPLIED AND INSTALLED BY DIV. 15.
8. FOR UNIT HEATER, DIV. 15 TO PROVIDE LINE VOLTAGE THERMOSTAT (T), DIV. 16. TO PROVIDE CONDUIT AND WIRING TO START/STOP UNIT HEATER.
9. CONDUITS TO MEDIUM SIZED TRANSFORMERS (300KVA-450KVA) ARE NOT TO BE BURIED IN THE ROOF SLAB RIGHT UP TO THE UNIT. INSTEAD, THEY ARE TO BE ROUTED ACROSS THE CEILING OF THE MECHANICAL PENTHOUSE AND BACK DOWN TO CONNECT TO THE TRANSFORMER.
10. ELEVATOR CONTROLLER SUPPLIED AND INSTALLED BY OTHERS. THIS CONTRACTOR SHALL PROVIDE INTERCONNECTION BETWEEN FIRE ALARM CONTROL PANEL AND ELEVATOR CONTROLLER.
11. REFER TO SPRINKLER DRAWINGS FOR FIRE PROTECTION DEVICE TO BE CONNECTED TO THE FIRE ALARM SYSTEM. THE DEVICE AND EQUIPMENT SHALL FORM AN INTEGRAL PART OF THE ELECTRICAL CONTRACT.
12. ALL OUTDOOR RECEPTACLES SHALL BE WEATHERPROOF (LEGRADE CAT* 3232TRUR-GRY FOR NON-GFCI AND CAT* 1595TRUR-GRY FOR GFCI) AND SHALL BE EQUIPPED WITH A WHILE IN USE CAST ALUMINUM COVERPLATE (LEGRANDE CAT* WUCAST1) COVERPLATE.

## KEY NOTES - ROOF:

(1) FOR CIRCUITING, REFER TO TABLE *1.

(2) ALL EXTERIOR LIGHTS SHALL BE CONTROLLED BY A TIMER/CONTACTOR LOCATED NEAR 'LP-R', CONNECT LIGHTS TO CIRCUIT AS SHOWN.

(3) EMERGENCY LIGHT FIXTURES IN LOCKERS, STORAGE, GARBAGE, UTILITY AND SERVICE ROOMS SHALL BE CONNECTED TO BOTH NORMAL AND EMERGENCY POWER AS PER DETAIL *21 OF DWG. E-35.

(4) ALLOCATE 2, 120V, 15A, CCTS FROM PANEL 'R' FOR MECHANICAL CONTROL CONTRACTOR COORDINATE WITH DIV. 15 FOR EXACT LOCATION.

## ELECTRICAL LEGEND

### LIGHTING

- FLUORESCENT LIGHT FIXTURE, TYPE AS INDICATED
- NIGHT LIGHT OR LIGHT CONNECTED TO EMERGENCY POWER
- CEILING MOUNTED/WALL MOUNTED LIGHT FIXTURE, NSCRIBED LETTER DENOTES TYPE
- POLE MOUNTED LIGHT FIXTURE, NSCRIBED LETTER DENOTES TYPE
- CAPPED CEILING LIGHT OUTLET
- TRACK LIGHT
- STRIP LIGHT
- UNDER CABINET FLUORESCENT LIGHT FIXTURE
- CEILING MOUNTED/WALL MOUNTED EXIT SIGN
- SINGLE/DUAL EMERGENCY LAMP REMOTE HEAD
- EMERGENCY BATTERY PACK
- OCCUPANCY SENSOR POWER PACKS
- S/S/S — SINGLE/TWO/THREE POLE, SINGLE/TWO/THREE THROW TOGGLE SWITCH RESPECTIVELY, ('3','4','P','D' DENOTES 3-WAY,4-WAY,PILOT LIGHT, DIMMER SWITCHED LIGHT RESPECTIVELY)
- MASTER LIGHTING SHUT-OFF SWITCH
- SENSOR WALL SWITCH PIR, SELF POWERED
- OCCUPANCY SENSOR, CEILING MOUNTED

### POWER

- REGULAR DUPLEX RECEPTACLE
- DUPLEX RECEPTACLE, GROUND FAULT INTERRUPT
- 3-2OR T-SLOT DUPLEX RECEPTACLE
- SINGLE RECEPTACLE, TYPE AND CONFIGURATION AS SPECIFIED FOR DRYER
- CONNECTION FOR OVEN/COOKTOP
- ABOVE COUNTER DEVICE
- CEILING MOUNTED DEVICES
- FLOOR MOUNTED DEVICES
- DISCONNECT SWITCH, NON-FUSED
- DISCONNECT SWITCH, FUSED
- COMBINATION STARTER
- FRACTIONAL HOTORFAN DIRECT CONNECTION
- DIRECT CONNECTION, SINGLE PHASE
- DIRECT CONNECTION, THREE PHASE
- THERMOSTAT
- DRYER SENSOR
- HEAT TRACE
- ELECTRICAL HEATER
- ELECTRICAL PANEL / SECURITY PANEL

### TELECOMMUNICATION

- TV/CABLE OUTLET
- TELEPHONE OUTLET
- TELEPHONE/TV CABLE (*SLT-PORT OUTLET)
- DATA OUTLET
- DATA/TELEPHONE OUTLET
- IN SUITE TELECOMM. BOX C/W RECEPTACLE
- WIFI LOCATION
- VIDEO INTERCOM
- RADIO RECEIVER

### SECURITY

- INTERCOM / ENTERPHONE
- INTERCOM WITH CAMERA
- PANIC BUTTON / PANIC INTERCOM STATION
- CARD READER
- AUTOMATIC RELEASE GARD ACCESS/RADIO RECEIVER
- ELECTRIC STRIKE
- MAGLOCK
- DOOR CONTACT / WINDOW CONTACT
- GLASS BREAK DETECTOR
- AUTOMATIC DOOR OPERATOR
- MOTION DETECTOR
- PUSH BUTTON
- SECURITY CAMERA

### LIFE SAFETY

- FIRE ALARM SMOKE DETECTOR
- SMOKE ALARM
- FIRE ALARM DUCT TYPE SMOKE DETECTOR
- FIRE ALARM HEAT DETECTOR
- FIXED TEMP. @ 135 °C DEGREE HEAT DETECTOR
- MOISTURE PROOF HEAT DETECTOR
- CO ALARM
- COMBINATION SMOKE & CO ALARM
- CO SENSOR / NO SENSOR
- FIRE ALARM MANUAL PULL STATION
- FIREFIGHTER'S HANDSET
- FIRE ALARM SPEAKER/STROBE, WALL MTD.
- FIRE ALARM SPEAKER, WALL MTD.
- FIRE ALARM SPEAKER/STROBE CEILING MTD.
- FIRE ALARM SPEAKER, CEILING MTD.
- FAAN — FIRE ALARM ANNUNCIATOR PANEL
- FACP — FIRE ALARM CONTROL PANEL

| DATE | NO. | DESCRIPTION | BY |
|---|---|---|---|
| | | MARK VOID ALL PRINTS DATED PREVIOUS TO FINAL DATE ABOVE | |
| 27/06/13 | 8 | ISSUED FOR S.C. 92-4 | S.T. |
| 05/06/13 | 7 | ISSUED FOR S.C. 92-4 | S.T. |
| 03/27/13 | 6 | ISSUED FOR SECURITY TENDER | S.T. |
| 27/02/13 | 5 | ISSUED FOR S.C. 92-4 | S.T. |
| 18/01/13 | 4 | RE-ISSUED FOR TENDER | S.T. |
| 29/11/12 | 3 | ISSUED FOR TENDER | S.T. |
| 27/09/12 | 2 | RE-ISSUED FOR PERMIT | S.T. |
| 05/09/12 | 1 | ISSUED FOR PERMIT | S.T. |

## REVISIONS

CONTRACTOR MUST CHECK AND VERIFY ALL DIMENSIONS AND CONDITIONS ON THE JOB AND REPORT ANY DISCREPANCIES TO THE CONSULTANT BEFORE PROCEEDING WITH THE WORK. THIS DRAWING IS THE PROPERTY OF THE ENGINEERS AND MUST BE RETURNED UPON COMPLETION OF THE WORK.

DRAWINGS ARE NOT TO BE SCALED


NOVA TREND ENGINEERING GROUP LTD

115 West Beaver Creek Road, Unit 31
Richmond Hill, Ontario L4B 3M1
Tel: 905 882-5448
Fax: 905 882-5447
Email: cad@novatrendeng.com


DRAWING TITLE:
ROOF FLOOR PLAN
ELECTRICAL LAYOUT

PROJECT TITLE:
ALEXANDRA PARK

38 CAMERON STREET, BLOCK 11
TORONTO ONTARIO

| DRAWN BY: | CHECKED BY: | SCALE: |
|---|---|---|
| S.O. | S.T. | 1:150 |
| DATE: | PROJECT NUMBER: | DRAWING NUMBER: |
| FEB. 13 | 1313 | E-29 of |


Drawing name: \\cadserver\Current Dwgs\1313 - Alexandra Park\DWG\1313E - 29 ROOF ELEC.dwg Plotted: Jul 28, 2015 - 11:42am