

POST TENDER ADDENDUM NO. M-1
MECHANICAL WORK
FOR
ALEXANDRA PARK

DELTERA

NOVATREND ENGINEERING GROUP LTD.

Date: December 11, 2014

1. Reference drawing M-43 (Issued)
 - a. Removed screw chiller and updated to centrifugal chiller as per acoustic engineer's comment. Chiller schedules updated.
 - b. Updated remarks section for fan coil unit as per Provident comments.