

SITE INSTRUCTION NO. M-3  
MECHANICAL WORK  
FOR  
ALEXANDRA PARK

DELTERA

NOVATREND ENGINEERING GROUP LTD.

---

Date: April 27, 2015

Changes in this notice are being issued to address the addition of sump pump for sub-slab drainage, cistern revisions, whirlpool and other site coordination items unless otherwise noted.

1. Reference drawing M-2 (Issued)
  - a. **Revision as per city's ongoing discussion:** Separated foundation and storm drains. Added pump and sand pit for foundation drains.
2. Reference drawing M-3 (Issued)
  - a. **Revision as per city's ongoing discussion:** Added a pumped pipe from new foundation pump on P-2 up to P-1.
  - b. **Revision due to Cistern change:** Chiller room exhaust revised.
  - c. **Revision due to Cistern change:** Fresh air duct from AHU revised.
3. Reference drawing M-4 (Issued)
  - a. **Revision due to Cistern change:** Chiller room exhaust revised.
  - b. **Revision due to Cistern change:** Fresh air duct from AHU revised.
4. Reference drawing M-5 (Issued)
  - a. **Revision due to Cistern change:** Moved storm pipe entering the cistern from the building.
  - b. **Revision as per city's ongoing discussion:** Added a foundation pumped pipe from new foundation pump on P-2.
  - c. **Revision:** Floor drains added from whirlpool room.
  - d. **Revision:** Whirlpool drain added.
  - e. **Revision due to Cistern change:** Floor drains moved in locker room.
5. Reference drawing M-10 (Issued)
  - a. **Revision:** Floor drains added in whirlpool room.
  - b. **Revision:** Whirlpool drain added.