

**BARRIER FREE UNIT CHART**

Unit	Quantity			Convertible 2BD+D	NOTES
	1BD	2BD	3BD		
PH1A			1		
PH1B		1			
PH1BB		1			
PH1C		1			
PH1CC		1			
PH1DD		1			
PH1GG		1			
PH1G		1			
11A		0			Cannot comply due to entrance condition (1 unit)
X 11B		1			Must revise main entrance closet and M bath entrance condition to comply.
11E		1			Cannot comply due to entrance condition (1 unit)
X 11F		1	1		Has been adjusted to comply as is.
X 11H		1			
X 11W		1			Cannot comply due to entrance condition (1 unit)
10M		0			Cannot comply due to entrance condition (1 unit)
8M		0			Cannot work due to MBR door condition (2 units).
X 7C		4			Has been adjusted to comply as is.
✓ 7E	4				Has been adjusted to comply as is.
7F	0				Cannot work due to entrance door non-compliance (4 units). Would need to move W/D out of the way and reconfigure closets.
X 7G		4			MBR closet width will need to reduce slightly to comply. Toilet door probably does not comply. Problem?
X 7H		4			MBR closet width will need to reduce slightly to comply. Toilet door probably does not comply. Problem?
X 7L	4				Bathroom will need to be modified to comply.
7M		0			Cannot comply due to entrance condition (1 unit)
X 7N		4		4	MBR entrance, closet and bath will need to be modified to comply.
X 7P		3			Linen closet in MBR to be removed.
X 4J		3			Master bath and closet can be adjusted to comply.
X 4K		3			Master bath and closet can be adjusted to comply.
X 2C		5		5	Has been adjusted to comply as is. DOES NOT COMPLY
✓ 2D	5				Has been adjusted to comply as is.
X 2E		1			Has been adjusted to comply as is. DOES NOT COMPLY.
X 2G		1			Master Bath and Kitchen can be adjusted to comply.
X 2M		1			Master Bath, Kitchen and entry closet can be adjusted to comply.
X 2P	1				Master bath and closet can be adjusted to comply. Move entry to adjacent wall.
2Q		0			Cannot comply (5 units)
X 2R	5				Kitchen island can be adjusted to comply. DOES NOT COMPLY
X 2V	9				Shift bathroom door and flip closet door to comply. DOES NOT.
X 2T	5				Bath and closet can be adjusted to comply. DOES NOT.

SEE COMMENT. MUST REUSE:

2 UNITS

22 UNITS

10 UNITS

14 | 19 | 1 = 34

(WILL NEED TO DESIGN ONE BF UNIT ON PH., PREFERABLY A 3BEDROOM UNIT)

1 BED 2 BED 3 BD

9 CONFIRMED BF SUITES

NEED 35 UNITS.

25 MOST EASILY CONVERTIBLE SUITES

Aug. 19, 2014.